

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7210-1608:100 Page 1 of 1

CATEGORY: Flame Detectors

LISTEE: Sierra Monitor Corporation, 1991 Tarob Court, Milpitas, CA 95035
Contact: Stephanie Loftus (408) 262-6611 FAX (408) 262-9042
sloftus@sierramonitor.com

DESIGN: Models 3100-01, 3100-02, 3100-03, 3100-04, and 3100-05 flame detectors. Units use infrared (IR), ultraviolet (UV) and visible sensors to detect flame energy. Suitable for indoor or outdoor use. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 15 - 32 VDC (nominal 24 VDC)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, voltage rating and FM label.

APPROVAL: Listed as flame detectors for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

XL: 7210-1526:101

06-26-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division