

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7210-1608:0101

CATEGORY: 7210 -- FLAME DETECTOR

LISTEE: SIERRA MONITOR CORPORATION 1991 Tarob Court, Milpitas, CA 95035
Contact: Stephanie Loftus (408) 262-6611 Fax (408) 262-9042
Email: sloftus@sierramonitor.com

DESIGN: Models 3200-01, -02, -03, -04, -05, -06, -07, -11, -12, -13, -15, -16, -17, -21, and -22 flame detectors. Units use infrared (IR) and ultraviolet (UV) sensors to detect flame energy. Suitable for indoor use only. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 - 30 VDC (nominal 24 VDC)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, voltage rating, and FM label.

APPROVAL: Listed as flame detectors for use with separately listed compatible control units. Authority having jurisdiction should be consulted prior to installation.

XLf: 7210-1526:0100

10-12-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division