

Triple IR (IR3) Flame Detector

Superior performance, reliability and immunity to false alarms

The 3600-I Triple IR (IR3) Flame Detector detects fuel and gas fires at long distances with the highest immunity to false alarms. The 3600-I IR3 can detect a 1ft² (0.1m²) gasoline pan fire at 215 ft (65m) in less than 5 seconds.

The 3600-I is the most durable and weather resistant flame detector currently on the market. Its features include a heated window, to eliminate condensation and icing; HART capabilities for digital communications; lower power requirements; and a compact, lighter design.

Due to increased reliability, the 3600-I Series is approved to IEC 61508 Safety Integrity requirements of SIL2 (TUV).



Features & Benefits

- Triple Spectrum Design - for long distance detection and high false alarm immunity
- Sensitivity Selection - to ensure no zone cross-over detection
- Automatic and Manual Built-In-Test (BIT) - to assure continued reliable operation
- Heated window - for operation in harsh weather conditions (snow, ice, condensation)
- Multiple output options for maximum flexibility and compatibility
 - Relays (3) for Alarm, Fault and Auxiliary
 - 0-20mA (stepped)
 - HART Protocol for maintenance and asset management
 - RS-485, Modbus Compatible
- High Reliability - MTBF - minimum 150,000 hours
- Approved to Safety Integrity Level 2 (SIL2 - TUV)
- 2-Year Warranty
- User Programmable via HART or RS-485
- Ex approved for Zone 1 hazardous area location
 - ATEX
 - IECEx
 - FM *
 - CSA *
- 3rd party Performance Tested
 - EN54-10 (LPCB)
 - FM3260 (FM)
 - DNV Marine Approval

* Option

Applications

- Offshore Oil & Gas installations
- Onshore Oil & Gas installations and pipelines
- Chemical plants
- Petrochemical plants
- Storage Tank farms
- Aircraft hangers
- Power Generation facilities
- Pharmaceutical industry
- Printing industry
- Warehouses
- Automotive industry
- Explosives & Munitions
- Waste Disposal facilities

Ordering Information

Model Number	Type	Wiring Config (Table1)	Temperature	Elec Entry	Housing	EX Approval
3600	- I = IR3	- 1 - 2 - 3 - 4 - 5	- 1 = 75C std - 2 = 85C	- 1 = M25 - 2 = 3/4" NPT	- S = SS - A = AL	- F = FM - C = ATEX/IECEX

Table 1: Wiring Options

All units are provided with RS-485 and HART enabled if mA output is used

Option	4-20mA	Fault Relay	Aux Relay	Alarm Relay
1 default	Sink	NC	--	NO
2	Source	NC	--	NO & NC
3	Source	NO	--	NO & NC
4	X	NC	NO	NO
5	X	NO	NO	NO

Model 3600-I

IR3 Flame Detector

Specifications:

Spectral Response	Three IR Bands			
Detection Range (at highest Sensitivity Setting for 1 ft ² (0.1m ²) pan fire)	n-Heptane: 215 ft (65m) Gasoline: 215 ft (65m) Diesel Fuel: 150 ft (45m) JP5: 150 ft (45m) *20" (0.5m) high, 8" (0.2m) with plume fire	Kerosene: 150 ft (45m) Ethanol 95%: 135 ft (40m) Methanol: 115 ft (35m) IPA (Isopropyl Alcohol): 135 ft (40m)	Methane*: 100 ft (30m) LPG*: 100 ft (30m) Polypropylene Pellets: 16 ft (5m) Office Paper: 33 ft (10m)	
Response Time	Typically 5 seconds			
Adjustable Time Delay	Up to 30 seconds			
Sensitive Range	4 Sensitive Ranges for 1 ft ² (0.1m ²) n-heptane pan fire from 50 ft (15m) to 215 ft (65m)			
Field of View	100° horizontal, 95° vertical			
Built-in-Test (BIT)	Manual and Automatic			
Temperature Range	Operating: -67°F to +167°F (-55°C to +75°C) Operating Option: -67°F to +185°F (-55°C to +85°C) Storage: -67°F to +185°F (-55°C to +85°C)			
Humidity	Up to 95% non-condensing (withstands up to 100% RH for short periods)			
Heated Options	To eliminate condensation and icing on the window			
Electrical Specifications				
Operating Voltage	24 VDC nominal (18-32 VDC)			
Power consumption	Standby: Max. 90mA (110mA with heated window) Alarm: Max. 130mA (160mA with heated window)			
Cable Entries	2 x 3/4" - 14NPT conduits or 2 x M25 x 1.5 mm ISO			
Wiring	12 - 22AWG (2.5mm ² - 0.3mm ²)			
Electrical Input Protection	According to MIL-STD-1275B			
Electromagnetic Compatibility	EM/RFI protected to EN61326-3 and EN61000-6-3			
Electrical Interface	The detector includes twelve (12) terminals with five (5) wiring options (factory set)			
Outputs				
Relays	Alarm, Fault and Auxiliary SPST volt-free contacts rated 5A at 30 VDC or 250 VAC			
4-20mA (stepped)	Sink (source option) configuration Fault: 0 +1mA BIT Fault: 2mA ±10% Normal: 4mA ±10%			Warning: 16mA ±5% Alarm: 20mA ±5% Resistance Loop: 100-600 ohms
HART Protocol	Optional HART communication on the 0-20mA analog current (FSK) - used for maintenance, configuration changes and asset management, available in mA source output wiring options			
RS-485	RS-485 Modbus compatible communication link that can be used in computer control installations			
Mechanical Specifications				
Materials	- Heavy-duty copper free aluminum (less than 1%), red epoxy enamel finish (ATEX Approval only)			
Enclosure Options	- Stainless Steel 316L with electro polish finish (FM or ATEX Approval)			
Mounting	Stainless Steel 316L with electro polish finish			
Dimensions	Detector: 4" x 4.6" x 6.18" (101.6 x 117 x 157 mm)			
Weight	Aluminum: 2.8 Lb (1.3 Kg) Stainless Steel 316L: 6.1 Lb (2.8 Kg) Tilt mount: 2.2 Lb (1.0 Kg)			
Environmental Standards	Meets MIL-STD-810C for Humidity, Salt & Fog, Vibration, Mechanical Shock, High Temp, Low Temp			
Water and Dust	IP66 and IP67 per En60529, NEMA 250 6P			
Approvals				
Hazardous Area				
ATEX & IECEx	Ex II 2 GD, Ex de IIB + H2 T5 (-55°C to + 75°C) Ex tD A21 IP66/X7 T 95°C			Ex de IIB + H2 T4 (-55°C to + 85°C) Ex tD A21 IP66/X7 T 105°C
FM / CSA *	Class I Div. 1, Groups B, C & D			Class III Div. 1, Groups E, F & G
Performance	EN54-10 (LPCB) FM-3260 (FM) DNV Marine Approval			
Reliability	IEC61508 - SIL-2 (TUV)			
Accessories				
Fire Simulator	20/20-310			
Tilt Mount	3600-01			
Weather Protector	777163			
Air Shield	777161			
Mini Laptop Kit	777820			
USB RS485 Harness Kit	794079-5			
Laser Pointer (Detector area coverage)	777166			

* Contact Sierra Monitor
Specifications subject to changes without notice

Sierra Monitor Corp 1991 Tarob Court Milpitas, CA 95035 USA (408) 262-6611 (800) 727-4377 Fax: (408) 262-9042

Visit our Web site: www.sierramonitor.com

E-Mail: sales@sierramonitor.com

© 2010 Sierra Monitor Corporation
Rev. 2/11