




TÜVRheinland®

ZERTIFIKAT  
CERTIFICATE

No.: 968/EZ 463.00/10

<b>Product tested</b>	Infra red and ultra-violet flame detector series	<b>Certificate holder</b>	Sierra Monitor Corporation 1991 Tarob Court Milpitas, CA 95035 USA
<b>Type designation</b>	Model 3600 - R, I, M, UB, LB, L4B		
<b>Codes and standards forming the basis of testing</b>	IEC 61508 Parts 1-7:1998 / 2000 EN 54-10:2002 + A1:2005 EN 50130-4:1995 + A1:1998 + A2:2003		
<b>Intended application</b>	The Model 3600 - R, I, M, UB, LB, L4B complies with the requirements of the relevant standards (SIL 2 acc. to IEC 61508) and can be used in applications for the detection of Hydrocarbon-based fuel and gas fires, hydroxyl and hydrogen fires as well as metal and inorganic fires up to SIL 2 acc. to IEC 61508.		
<b>Specific requirements</b>	The safety notes in the User Manuals of the Model 3600 - R, I, M, UB, LB, L4B shall be considered.		
This certificate is valid until 2014-02-27.			



The test report-no.: 968/EZ 463.00/10 dated 2010-09-27 is an integral part of this certificate.

The holder of a valid licence certificate for the product tested is authorized to affix the test mark shown opposite to products, which are identical with the product tested.

**TÜV Rheinland Industrie Service GmbH**  
Geschäftsfeld ASI

Automation, Software und Informationstechnologie  
Am Grauen Stein, 51105 Köln  
Postfach 91 09 51, 51101 Köln

Köln, 2010-09-27

Certification Body of  
TÜV Rheinland Industrie Service GmbH

Dipl.-Ing. Stephan Häb