



Certificate

Certificate no.

CU 72051639 01

License Holder:

Sierra Monitor Corporation
1991 Tarob Court
Milpitas CA 95035
USA

Manufacturing Plant:

Sierra Monitor Corporation
1991 Tarob Court
Milpitas CA 95035
USA

Test report no.: USA-HN 30580501 001

Client Reference: Michael C. Farr

Tested to: UL 60950-1:2003
CAN/CSA-C22.2 No.60950-1-03

Certified Product: Cell Site Environment Control System

License Fee - Units

Model Designation: 2435 Intelesite with accessories: 7
1) 2435-CCM, 2) 2435-FCM, 3) 2435-HCM

Rated Voltage: 1),2) DC -48V (DC -36 to -60V max.)
3) AC 24V, 60Hz

Rated Current: 1A
Protection Class: III

Special Remarks: Replaces Certificate CU72050637.

7

Appendix: 1, 1-2

Inh. = 724024 / Deb. = 724024 / Fert. = 724024

Licensed Test mark:

Signatures

Date of Issue
(day/mo/yr)
03/06/2005



Stephan Schmitt
President

Dipl.-Ing. M. Raap
QA Certification Officer