

Declaration of IP Rating

Fixed Flame and Gas Detector Information Sheet
Propel Declaration No. DEC-0003



CERTIFICATION STATEMENT FOR THE INGRESS PROTECTION OF THE RAIN SHIELD ACCESSORY

Model Numbers: 5311-00 and 5311-02

Tests Conducted Between: 30 August 2019 through 27 November 2019

This document certifies that the products detailed above, to which this declaration relates, conforms to the relevant parts of the following standard:

IEC 60529:1992 Inc Amendments Nos 1 and 2

Deviations from Standard: None

The model 5311-00 and 5311-02 are IP55 compliant, provided they are installed per the Manufacturer's instructions.

IP55 claims that the ingress of dust is not entirely prevented, but it must not enter in sufficient quantity to interfere with the satisfactory operation of the equipment, and that water projected by a nozzle (6.3 mm [0.25 in]) against the enclosure, from any direction, shall have no harmful effects.

29 November 2019

F GIANGREGORIO

Senior Engineer

Sierra Monitor Corporation, an MSA Company

1991 Tarob Court, Milpitas, California 95035 USA