



Certificate of Compliance

Certificate: 2417174

Master Contract: 251632

Project: 70032771

Date Issued: 2015-06-03

Issued to: Sierra Monitor Corporation
1991 Tarob Court
Milpitas, California 95035
USA

Attention: Tuan Ho

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Yiu-Chi (Edwin)
Ko
Yiu-Chi (Edwin) Ko

PRODUCTS

CLASS - C481213 - SIGNAL APPLIANCES-Signal Systems

CLASS - C481285 - SIGNAL APPLIANCES-Signaling Systems - Certified to US Standards

FieldServer Protocol Translator, Model FS-B35XX-05; Input rated 12-30 V dc, 24 V ac, 12 Watts.

Notes:

1. Model FS-B35XX-05, where X can be any number from 0 to 9 depending on the different port configurations.
2. Model FS-B35XX-05 has been evaluated to operate in ambient temperature of 60°C.
3. The above model is a certified component of other certified equipment, where the suitability of the combination is to be determined by CSA Group.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No 205-12 - Signal Equipment

UL 916 (4th Edition) - Energy Management Equipment



Supplement to Certificate of Compliance

Certificate: 2417174

Master Contract: 251632

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70032771	2015-06-03	Update report to cover report update to CSA C22.2 No. 205-12, UL 916 4 th Edition and change of class from 4812 05 to 4812 13.
2469584	2011-10-28	Update Report 2417174 to change Class from 4812 06/86 to 4812 05/85.
2417174	2011-05-13	FieldServer Protocol Translator, Model FS-B35XX-05. (C/US)