

1 DESCRIPTION

The Optomux Driver allows the FieldServer to transfer data to and from devices over either RS-232 or RS-485 using the Optomux Driver protocol. The Optomux driver is a client only driver and can poll an Optomux protocol compliant device but not emulate one.

The Optomux protocol provides a large command set. Many of the commands are used for OPTO22 device configuration. This driver supports the full command set and thus the driver may be used to configure as well as to poll OPTO22 devices.

1.1 Operating Methods

The Optomux driver provides three methods of operation. Users may use any combination of methods.

1.1.1 Static Operation

The devices to be polled/commanded are configured using the FieldServer CSV file. If the hardware configuration is fixed and known then this is a suitable method.

1.1.2 Dynamic Operation

The commands set can be configured by changing the values in the FieldServer's Data Arrays. This data driven operating mode is suitable if the hardware configuration may change or if hardware settings may change dynamically or to change some aspect of the hardware configuration without changing the CSV file and resetting the FieldServer.

1.1.3 Triggered Operation

This operating mode allows commands to be triggered by changing the value in the FieldServer's Data Arrays. This operating mode is useful if requiring an action triggered by a remote device.

1.2 Statistics and Command Responses

All FieldServer drivers report communication statistics that allow the operation of the driver to be monitored.

In addition to the standard statistics, this driver exposes the communication statistics for each port by presenting them in a user specified data array where they can be monitored by a remote device or HMI system.

The Optomux driver also exposes the response status to each poll and command (if required) by writing the response statuses to a user specified data array. This useful feature allows remote devices to check whether a command has been completed successfully.

1.3 Connection Facts

FieldServer Mode	Nodes	Comments
Client	256	
Server	N/A	Server side is not supported. See description.

2 FORMAL DRIVER TYPE

Serial

Client Only

3 COMPATIBILITY

FieldServer Model	Compatible
FS-B35 Series	Yes
ProtoNode/ProtoAir	Yes
QuickServer FS-QS-10xx	No
QuickServer FS-QS-12xx	Yes
QuickServer FS-QS-20xx	No
QuickServer FS-QS-22xx	Yes

4 CONNECTION INFORMATION

Connection Type: RS-485 (Two wire, Half-Duplex)
 Baud Rates: At the time of publication of this manual the OPTO22 devices support standard baud rates in the range 300-38400.
 Data Bits: 7,8
 Stop Bits: 1
 Parity: Odd, Even, None
 Multidrop Capability: No

5 DEVICES TESTED

Device	Tested (FACTORY, SITE)
OptoMux (by Opto22 Inc.)	SITE

6 COMMUNICATIONS FUNCTIONS

6.1 Supported Commands/Queries

POWER UP CLEAR
 RESET
 SET TURN-AROUND DELAY
 SET WATCHDOG DELAY
 SET WATCHDOG DELAY (Analog)
 SET PROTOCOL
 IDENTIFY Optomux TYPE
 SET ENHANCED DIGITAL WATCHDOG
 SET ENHANCED ANALOG WATCHDOG
 SET TIMER RESOLUTION
 SET TEMPERATURE PROBE TYPE
 CONFIGURE POSITIONS
 CONFIGURE AS INPUTS
 CONFIGURE AS OUTPUTS
 READ MODULE CONFIGURATION
 WRITE OUTPUTS
 ACTIVATE OUTPUTS
 DEACTIVATE OUTPUTS
 READ STATUS
 SET LATCH EDGES
 SET LATCH OFF TO ON
 SET LATCH ON TO OFF
 READ LATCHES
 READ AND CLEAR LATCHES
 CLEAR LATCHES
 START/STOP COUNTERS
 START COUNTERS

STOP COUNTERS
 READ COUNTERS
 READ AND CLEAR COUNTERS
 CLEAR COUNTERS
 SET TIME DELAY
 INITIATE SQUARE WAVE
 HIGH RESOLUTION SQUARE WAVE
 RETRIGGER TIME DELAY
 GENERATE N PULSES
 START ON PULSE
 START OFF PULSE
 SET TRIGGER POLARITY
 TRIGGER ON POSITIVE
 TRIGGER ON NEGATIVE
 READ PULSE COMPLETE BITS
 READ DURATION COUNTERS
 READ AND CLEAR DURATION COUNTERS
 CLEAR DURATION COUNTERS
 WRITE ANALOG OUTPUTS
 READ ANALOG OUTPUTS
 UPDATE ANALOG OUTPUTS
 READ ANALOG INPUTS
 READ AND AVERAGE INPUT
 START INPUT AVERAGING
 READ AVERAGE COMPLETE BITS
 READ INPUT AVERAGE DATA
 READ TEMPERATURE INPUTS
 READ AVERAGE TEMPERATURE INPUTS
 SET INPUT RANGE
 READ OUT-OF-RANGE LATCHES
 READ AND CLEAR RANGE LATCHES
 CLEAR OUT-OF-RANGE LATCHES
 READ LOWEST VALUES
 CLEAR LOWEST VALUES
 READ AND CLEAR LOWEST VALUES
 READ PEAK VALUES
 CLEAR PEAK VALUES
 READ AND CLEAR PEAK
 CALCULATE OFFSETS
 SET OFFSETS
 CALCULATE AND SET OFFSETS
 CALCULATE GAIN COEFFICIENTS
 SET GAIN COEFFICIENTS
 CALCULATE AND SET GAIN
 SET OUTPUT WAVEFORM R
 IMPROVED OUTPUT WAVEFORMS

7 UNSUPPORTED FUNCTIONS AND DATA TYPES

The driver was developed and tested using REV1 equipment. The basis for development was the OPTOMUX PROTOCOL USER'S GUIDE dated April 2000.

Baud rates From Rev1 onwards, additional baud rates were supported.
Command Set From Rev1 onwards, the following commands are supported.

Digital	Analog
SET ENHANCED DIGITAL WATCHDOG	SET ANALOG WATCHDOG USER-DEFINED VALUE
SET TIMER RESOLUTION	SET ANALOG WATCHDOG
READ MODULE CONFIGURATION	READ MODULE CONFIGURATION
HIGH RESOLUTION SQUARE WAVE	SET TEMPERATURE
RETRIGGER TIME DELAY	PROBE TYPE
GENERATE n PULSES	
START ON PULSE	
START OFF PULSE	

7.1 Operational Differences – Old Optomux Brain Boards

This protocol manual applies to Optomux units labeled "REV 1" and above. If the Optomux brain board (applies to B1 and B2 only) does not have a revision label, you have a very old Optomux unit and should be aware of the following differences. Brain board model B3000 is newer than "REV 1".

The following notes are extracted from the OPTOMUX PROTOCOL USER'S GUIDE - April 2000.

7.1.1 Digital Brain Boards (B1)

- The "REV 1" (or greater) Optomux units will notify the host that a serial watchdog has timed out by responding to the first command after a serial watchdog time-out with an N06cr error code. The command will not be executed. This is similar to a power-up operation. This error code will not be sent in response to a "POWER UP CLEAR" command.
- Pulse duration counters are edge triggered with the newer Optomux brain boards. The previous versions were level triggered.

- Maximum counter frequency is now 400 Hz, 50 percent duty cycle (minimum ON or OFF pulse time is 1.25 milliseconds). Use of the "GENERATE n PULSES" command will degrade counter frequency to 350 Hz maximum.
- The baud rate may now be changed without cycling power to the Optomux. Additional baud rates of 600, 2,400, 4,800, and 38,400 are now supported when using "REV 1" brain boards or above.
- Two question mark characters (??) may be used instead of the calculated checksum characters in command strings.

7.1.2 Analog Brain Boards (B2)

- The "REV 1" (or greater) Optomux units will notify the host that a serial watchdog has timed out by responding to the first command after a serial watchdog time-out with an N06cr error code. The command will not be executed. This is similar to a power-up operation. This error code will not be sent in response to a "POWER UP CLEAR" command.
- With "REV 1" (or greater) brain boards, averaging is performed using a continuous running average with a sample rate of 100 milliseconds. The number of samples to average is set with the "START INPUT AVERAGING" command as before, however, there is no need to restart the averaging after the number of samples has been reached. The "READ AVERAGE COMPLETE BITS" command indicates that the number of samples to average has been reached. The running average calculation used by Optomux is as follows (where n is the number of samples):

$$\text{New Average} = ((n-1) (\text{Old Average}) + (\text{New Reading}))/n$$
- The baud rate may now be changed without cycling power to the Optomux. Additional baud rates of 600, 2,400, 4,800, and 38,400 are now supported when using "REV 1" brain boards or above.
- Two question mark characters (??) may be used instead of the calculated checksum characters in command strings.