

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 7210-1608:0101

**CATEGORY:** 7210 -- FLAME DETECTOR

**LISTEE:** SIERRA MONITOR CORPORATION 1991 Tarob Court, Milpitas, CA 95035  
Contact: Stephanie Loftus (408) 262-6611 Fax (408) 262-9042  
Email: sloftus@sierramonitor.com

**DESIGN:** Models 3200-01, -02, -03, -04, -05, -06, -07, -11, -12, -13, -15, -16, -17, -21, and -22 flame detectors. Units use infrared (IR) and ultraviolet (UV) sensors to detect flame energy. Suitable for indoor use only. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 12 - 30 VDC (nominal 24 VDC)

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, voltage rating, and FM label.

**APPROVAL:** Listed as flame detectors for use with separately listed compatible control units. Authority having jurisdiction should be consulted prior to installation.

**XLf:** 7210-1526:0100

10-12-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**  
*Fire Engineering Division*