


LICENCE CERTIFICATE

for TÜV Rheinland Test Mark

No. 968/EZ 463.01/14

Licence holder: Sierra Monitor Corporation 1991 Tarob Court Milpitas, CA 95035 United States of America	Manufacturer / Manufacturing plant: Spectrex Inc. 218 Little Falls Road 1 Cedar Grove NJ 07009 United States of America
--	---

Date of application:	File ref.:	Date of issue:
2014-04-22	968/EZ 463.01/14	2014-04-22

Test Mark:  <div style="border: 1px solid gray; padding: 2px; font-size: 8px;"> Functional Safety Type Approved www.tuv.com ID 0600000000 </div>	For products that are in conformity with the certified product described below, the holder of this Licence Certificate is authorized to use the TÜV Rheinland Test Mark shown on this page by affixing the same to the product and by using it in print and electronic media for information and advertising purposes for the certified product. All terms of the currently valid Regulation of Certification and Test Mark Regulation have to be considered. The validity for use of the Test Mark is bound to the existence of a valid certificate for the certified product.
--	--


Annual fee units for use of the Test Mark:	Units of fee: 6
---	----------------------------------

Certified product, identification of the device:	
Kind of product:	Infra-red and ultra-violet flame detector series
Type designation:	Model 3600 - R, I, M, UB, LB, L4B
Technical data:	Spectral response: UV: 0.185 - 0.260 µm IR: 4.4 - 4.6 µm Response time: Typ.: 3 seconds Supply voltage: 24 V Max. power consumption: 3.24 W Max. current: 160 mA Output: 0 - 20 mA Fault relay Alarm relay
Special remarks:	Report-No.: 968/EZ 463.01/14 dated 2014-04-22 and Certificate No.: 968/EZ 463.01/14 dated 2014-04-22

TÜV Rheinland Industrie Service GmbH
 Bereich Automation
 Funktionale Sicherheit
 Am Grauen Stein, 51105 Köln

2014-04-22
Date

Stamp of the Certification Body


 Dipl.-Ing. Stephan Häb