

MET LABORATORIES, INC. CERTIFICATION RECORD



The applicant named below has been authorized by MET Laboratories, Inc. to represent the product(s) listed in this record as "MET Certified" and to mark this/these product(s) according to the terms and conditions of the MET Mark Utilization Agreement, MET Listing Reports, and the applicable marking agreements. Only the product(s) bearing the MET Mark and under a follow-up service are considered to be included in the MET Certification program. This certification has been granted under a System 3 program as defined in ISO Guide 67.

FILE NUMBER: E113697

APPROVAL DATE: February 19, 2014

REVISED: -

PRODUCT(S)	MODEL(S)	ELECTRICAL RATINGS
Sentry IT Controller	5000-XX-IT-Y-ZZZZ-SNN-0	120/240VAC, 3A, 50/60Hz, optionally, can be powered .by DC power supply 24Vdc

STANDARD NUMBER	STANDARD TITLE	EDITION
UL60950-1/CSA C22.2 No. 60950-1	Safety of Information Technology Equipment	Second

MET LABORATORIES, INC. requires that any and all changes proposed in the previously identified product(s), that affects the information contained in the above referenced listing report, must be submitted to MET for evaluation prior to implementation to assure continued MET Certification status.

The above identified product(s) has/have been submitted by the applicant:

APPLICANT:

Sierra Monitor Corp.
1991 Tarob Court
Milpitas, CA 95035
USA

The covered products shall be subjected to follow-up inspections to ensure that the Certified product(s) are identical to the representative product sample evaluated by MET LABORATORIES, INC. and that all manufacturer's responsibilities are being fulfilled as specified in the MANUFACTURING RESPONSIBILITY section of the Certification report.

Rick Cooper
Director of Laboratory Operations,
Safety Laboratory



*MET Laboratories, Inc. is accredited by OSHA and the Standards Council of Canada.
The Nation's First Nationally Recognized Testing Laboratory*

NRTL